

Check fire extinguishers

Fire extinguishers are located in the following areas:

- Kitchen
- Wood Shop
- Maintenance Room
- Blacksmithing
- Front Entrance

For each fire extinguisher:

1. Verify that all fire extinguishers are pressurized (indicator is in the green range).
2. Verify that they are within their inspection time frame.

If any fire extinguishers within a year of being out of inspection, file a tool report to handle retesting/replacement.

Tool report: <https://airtable.com/appbIIORlmbIxNU1L/shrluff2WSzy8c3xd>

Revision #1

Created 11 February 2025 17:22:42 by Scott Martin

Updated 22 March 2025 17:05:39 by Scott Martin