

# Check workshop outlets

Check all electrical outlets on ceiling drops and floor runs for loose outlets and/or cable clamps, improper use of "punch-out" junction boxes, or improper use of "power strips" not installed and used in accordance with instructions included in the listing, labeling or certification.

If you find any loose parts on the outlet drops, submit a maintenance request.

Maintenance request: <https://airtable.com/appbIIORlmbIxNU1L/shrluff2WSzy8c3xd>

---

Revision #1

Created 11 February 2025 17:31:45 by Scott Martin

Updated 22 March 2025 17:05:39 by Scott Martin